

STATEMENT OF COMPLIANCE

The product Photovoltaic Module has been tested by UL India Private Limited and found to comply in accordance with the Standard indicated on this report.

Project Number: 4790618738.8.1

Report Number: 4790618738.8.1-S1 Dated 21 March 2023

Test Location: China Telecommunication Technology Labs (vendor)

Issued to: SOLEX ENERGY LTD
PLOT NO 1 A BLOCK 938, TADKESHWAR,
KIM MANDVI ROAD, MANDVI,
SURAT, GUJARAT, GUJARAT, 394110

Tested Model: SMFB72HM10-545
(Refer to Report No. 4790618738.8.1-S1 for BOM and Test details)

Models Covered*: Mono-Crystalline Photovoltaic Modules with maximum 1500V system voltage:

144 Half cut cell:

SMF72HM10-555, SMF72HM10-550, SMF72HM10-545, SMF72HM10-540, SMF72HM10-535, SMF72HM10-530.

SMFB72HM10-555, SMFB72HM10-550, SMFB72HM10-545, SMFB72HM10-540, SMFB72HM10-535, SMFB72HM10-530.

132 Half cut cell:

SMF66HM10-505, SMF66HM10-500, SMF66HM10-495, SMF66HM10-490, SMF66HM10-485, SMF66HM10-480

SMFB66HM10-505, SMFB66HM10-500, SMFB66HM10-495, SMFB66HM10-490, SMFB66HM10-485, SMFB66HM10-480

120 Half cut cell:

SMF60HM10-460, SMF60HM10-455, SMF60HM10-450, SMF60HM10-445, SMF60HM10-440
SMFB60HM10-460, SMFB60HM10-455, SMFB60HM10-450, SMFB60HM10-445, SMFB60HM10-440

108 Half cut cell:

SMF54HM10-415, SMF54HM10-410, SMF54HM10-405, SMF54HM10-400
SMFB54HM10-415, SMFB54HM10-410, SMFB54HM10-405, SMFB54HM10-400

Standard(s): IEC 60068-2-68 Edition 1.0, 1994-08- Environmental Testing- Part 2: Dust and Sand.

Test Condition: Test method: Lc2

Dust/Sand type: Quartz, SiO₂

Dust/Sand concentration: 10 g/m³ ± 3 g/m³

Air velocity: 20 m/s ± 2 m/s


Duration: 8 hours (4 hours for front and 4 hours for rear side)

* Manufacturer declares that samples submitted for evaluation are representative of the covered models and produced using the same materials, components, equipment, and processes. Details of the bill of materials are provided in the test report. Any change in design, materials, components, equipment, and processes may require retesting to maintain the compliance.

Disclaimer: Test results apply only to the sample(s) actually tested by UL India Private Limited or its vendor. The client provided all of the test samples for testing by UL. UL did not select the samples or determine whether the samples provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The client and or manufacturer are solely and fully responsible for conformity of all products to all applicable standards, specifications or requirements. UL Logo and Marks shall not be used in connection with the above tested product(s). Only those products bearing the UL Listing and Classification Marks should be considered as being covered by UL's Listing, Classification and Follow-Up Service. Look for the UL Listing and Classification Mark on the product.

Issued By:

Authorized By



Kantha Raju H S
UL India Private Limited

N Srimathy
UL India Private Limited